

Godawari Municipality

Office of the Godawari Municipal Executive

Bajrabarahi, Lalitpur

AMEDMENT NOTICE

Invitation for Sealed Quotation for the Supply, Installation and Commissioning of Solar Street Light Ward No.1, Godamchaur, Contract Identification No:-GodawariMunic./Bajrabarahi,Lalitpur/G/SQ/01/075/76

It is notify that first amendment has been made in the Technical specification (first date of publication: 2075/08/09) for the supply, Installation and Commissioning of Solar Street Light ward no.1, Godamchaur as follows:

- i. Section IV List of Goods and Related Services, Delivery and Completion Schedule 1.1.1.2, 1.1.2.1, 1.1.2.2 and 1.1.2.3 item description column is deleted entirely and read as follows:
1.1.1.2 40-42 watt, 1.1.2.1 Li-Ion (12±10%) V at least 75AH, 900Whr/ LiFePO4 Ion (12±10%) V, 900Whr, Single Arm Galvanized Pole (at least 120 kg), Interconnecting wires & other accessories (Nut-Bolt, earthing, metal frame with logo of Municipality, Nepal Red cross Society and Name, Contact Address of Suppliers)
- ii. Section V Technical Specification: electrical machinery apparatus equipment and consumables 1.1.1.2, 1.1.2.1, 1.1.2.2 and 1.1.2.3 is deleted entirely and read as follows:
1.1.2 40-42 watt, 1.1.2.1 Li-Ion (12±10%) V at least 75AH, 900Whr/ LiFePO4, 900Whr. Single Arm Galvanized Pole (at least 120 kg), Interconnecting wires & other accessories (Nut-Bolt, earthing, metal frame with logo of Municipality, Nepal Red cross Society and Name, Contact Address of Suppliers)
- iii. Technical Specification: Battery specification S.N 1.7, S.N.1.14 and solar street light specification S.N 4.9 is deleted entirely and read as follows:

For Li-Ion (12±10%) V at least 75AH the capacity of battery must not be less than 900Whr OR, LiFePO4 (12±10%) V, not less than 900Whr, Battery Life Cycle: At least 3000 cycle, lamp rated total power 40-42 watt

The addenda of the amendment will be issued in the Pre-qualification document.

Chief Administrative Officer